


DEQ Septage Receiving Facility Checklist

Page 1

Name of Septage Receiving Facility:
Benton Harbor - St. Joseph Joint WWTP

DEQ Reviewer: M. Campbell
Review Date: 6/9/06



Address of Septage Receiving Facility:
**269 Anchors Way
St. Joseph, MI 49085**

Facility Contact: **Mr. Timothy J. Lynch, Manager**
Telephone Number: **269-983-7719**

The following information must be submitted in the Operation Plan
in order to receive DEQ approval:

<u>Requirement</u>	<u>Yes</u>	<u>No</u>	<u>Comments</u>
1. Location of septage RF.	X		
2. Hours of operation.	X		6 a.m. to 6 p.m. M - F
3. Categories of septage waste the RF will receive.	X		Domestic septage only. No industrial or commercial waste.
4. If food establishment septage is accepted, how is the RF ensuring that the FES meets the 1:3 ratio mandated by law? (Not OP req't.)			FES is not accepted.
5. *Fee structure charged to hauler.	X		Currently 3.5¢, changes to 4¢ per gallon on July 1, 2006.
6. *Service area (septage acceptance) description of RF defined in detail.	X		15 radial miles around facility. Map provided in June 7, 2006, response letter.
7. Notice of proposed operation plan:			
a) Was it mailed to county HD and legislative body of each city, village and township located in whole or in part of the service area?	X		In a letter dated June 7, 2006, the plant manager noted that they contacted the health department and local unit of governments (see list in letter).

DEQ Septage Receiving Facility Checklist

Page 2

Name of Septage Receiving Facility: **Benton Harbor - St. Joseph Joint WWTP**

<u>Requirement</u>	<u>Yes</u>	<u>No</u>	<u>Comments</u>
7. Notice of proposed op. plan:			
b) Was it public noticed in the local newspaper?	X		
c) Was it posted on the facility website?		N.A.	The facility does not maintain a website.
8. Did the notice contain the following?			
a. Statement that the RF proposed to or is currently receiving and will continue to receive septage waste for treatment.	X		
b. Statement in the notice that the proposed operating plan is available for review during normal work hours.			
c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice.	X		
d. Receiving facility capacity.			
I) Hydraulic capacity:	X		20,000 gpd is the max. They average 3,000 gpd.
II) Organic capacity:		X	Not given. But at 20,000 gpd their BOD would be ~ 1,500 lbs./day.
*III) Wet weather operation considerations (CSO & SSO)			Not mentioned.
9. Other conditions established for the RF.	X		They reserve the right to suspend service to a hauler whose actions are harmful to the plant.

BENTON HARBOR – ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT

Producing clean water for the environment

June 2, 2006

Mr. Matthew Campbell
Septage Waste Program Coordinator
MDEQ Water Bureau
PO Box 30273
Lansing, MI 48909-7773

RECEIVED
MICH DEPT OF ENVIRONMENTAL QUALITY

JUN 7 2006

Water Division
Wastewater Section
WELL CONSTRUCTION UNIT

**Subject: Septage Waste Treatment Operating Plan
Additional Information**

Dear Mr. Campbell:

In response to your April 21, 2006 letter I am providing the following comments and information relating to the Joint Plant's Septage Waste Treatment Operating Plan.

Under the public notice section of your letter; The Joint Plant does not maintain a website.

The proposed operating plan was not mailed to the local county health department and each legislative body within the Joint Plant's service area. In accordance with Act 451 Section 11715b.6.c, the following action was taken:

The Berrien County Health Department and the legislative body of each city, village and township located in whole or in part of the service area of the Joint Plant were sent a notice stating where the operating plan was available for review during normal business hours. The plant received and accommodated one inquiry in response to this notice.

With regards to the service area section of your letter, the Joint Plant's service area consists of the following municipalities:


City of St. Joseph
St. Joseph Township
Village of Stevensville
Lincoln Township

City of Benton Harbor
Benton Township
Village of Shoreham
Royalton Township

A map of Berrien County with the Joint Plant service area outlined is attached.

If you have any further questions or comments relating to this matter, please contact me.

Sincerely,


Timothy J. Lynch
Plant Manager

Enclosure

BENTON HARBOR-ST. JOSEPH Land Use Map




JOINT WASTEWATER TREATMENT PLANT

269 ANCHORS WAY

ST. JOSEPH, MI 49085

Year 2000

Service Area



EXISTING SERVICE AREA BOUNDARY

POTENTIAL FUTURE SERVICE AREAS





JENNIFER M. GRANHOLM
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING



STEVEN E. CHESTER
DIRECTOR

January 31, 2006

Mr. Timothy J. Lynch, Plant Manager
Benton Harbor – St. Joseph Joint WWTP
269 Anchors Way
St. Joseph, Michigan 49085

Dear Mr. Lynch:

SUBJECT: Septage Receiving Facility Operating Plan
Benton Harbor – St. Joseph Joint WWTP

Review of the Benton Harbor – St. Joseph Joint Wastewater Treatment Plant (WWTP) received on October 13, 2005, is complete. The purpose of the review was to ensure that the plan addressed all of the required elements of Part 117, Septage Waste Services, Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. The operating plan is approved under the condition that the following items are addressed and sent to this office within 60 days (March 31, 2006).

The public notice requirements are as follows:

- Publish notice of the proposed operating plan in a newspaper of general circulation in the area where the receiving facility is located.
- If the person maintains a Web site, post notice of the proposed operating plan on its Web site.
- Notice of a proposed operating plan shall contain all of the following:
 - (a) A statement that the receiving facility continues to receive septage waste for treatment.
 - (b) A copy of the proposed operating plan or a statement where the operating plan is available for review during normal business hours.
 - (c) A request for written comments on the proposed operation of the receiving facility and the deadline for receipt of such comments, which shall be not less than 30 days after publication, posting, or mailing of the notice.

After the deadline for receipt of comments, the person proposing to operate a receiving facility may modify the plan in response to any comments received and shall submit a summary of the comments and the current version of the proposed operating plan to the Department of Environmental Quality (DEQ) for approval.

Receiving facility capacity:

- Does the Benton Harbor – St. Joseph Joint WWTP have any wet weather operation considerations (combined sewer or sanitary sewer overflows).

Mr. Timothy J. Lynch
Page 2
January 31, 2006

The receiving facility must operate in accordance with the approved plan. If a change in operations or conditions is anticipated, please file an amendment to the plan at least 30 days prior to the proposed date for implementation. Please note that this approval is further conditioned such that the identified service areas restrict only the disposition of septic tank waste pumped within those areas. Land application of septage pumped from outside the service areas may continue to be land applied to DEQ authorized land-application sites within the identified boundaries.

If you have any questions regarding this matter, please contact me at the number below.

Sincerely,

A handwritten signature in black ink that reads "Matthew Campbell". The signature is fluid and cursive, with the first name "Matthew" and last name "Campbell" clearly distinguishable.

Matthew Campbell
Septage Waste Program Coordinator
On-Site Wastewater Unit
Drinking Water and Environmental Health Section
Water Bureau
517-335-4178

MCC:DLR

cc: Mr. Gary T. Witkowski, R.S. Environmental Health Services Manager, Berrien County
Health Department
Mr. Richard Falardeau, Water Bureau, DEQ

BENTON HARBOR – ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT

Producing clean water for the environment

February 22, 2006

Mr. Matthew Campbell
Septage Waste Program Coordinator
MDEQ Water Bureau
PO Box 30273
Lansing, MI 48909-7773

RECEIVED
MICH DEPT OF ENVIRONMENTAL QUALITY

FEB 24 2006

Water Division
Groundwater Section
WELL CONSTRUCTION UNIT

**Subject: Septage Waste Treatment Operating Plan
Additional Information**

Dear Mr. Campbell:

In accordance with your January 31, 2006 letter of conditional approval and as we discussed, I am providing additional information relating to the Joint Plant's Septage Waste Treatment Operating Plan.


Specifically, you asked for verification that the public notice requirements of the plan have been fulfilled. I have enclosed a copy of the Affidavit of Publication along with the notice published in the local newspaper with all required information. No public comments were received on the plan.

The other information requested relates to the receiving facility capacity. This information is available in the Joint Plant's Septage Waste Treatment Operating Plan, enclosed (2nd and 3rd paragraphs). It should also be noted the plant can suspend or refuse service to anyone when such actions may be harmful to the operation and treatment of the facility or its processes such as during times of abnormally high influent flows. This stipulation is found in Section F of the Joint Plant's Supplemental Septage Dumping and Treatment Rules and Regulations approved and adopted by the Benton Harbor – St. Joseph Wastewater Treatment Plant Joint Board of Commissioners on December 16, 2004. I have also enclosed a copy of this document for your review. In summary, the following documents are enclosed for your review:

- A. Affidavit of Publication along with the notice published in the local newspaper
- B. The Joint Plant's Septage Waste Treatment Operating Plan
- C. The Joint Plant's Supplemental Septage Dumping and Treatment Rules and Regulations

I trust this will satisfy the requirements for final approval of our plan. If you have any questions or comments relating to this matter please contact me.

Sincerely,


Timothy J. Lynch
Plant Manager

Enclosures

RECEIVED
9-22-05

Voucher

AFFIDAVIT OF PUBLICATION

PUBLIC NOTICE

The Benton Harbor - St. Joseph Joint Wastewater Treatment Plant is currently and proposes to continue to receive septage waste at 269 Anchors Way, St. Joseph, Michigan 49085.

The Joint Plant's Septage Waste Treatment Operating Plan is on file and available for review upon request at the plant during normal weekday business hours.

Written comments on the operating plan will be accepted until October 10, 2005.

Legals

For more information contact
Timothy J. Lynch
Manager (269)
983-7719
HP/adv. September 8, 2005

STATE OF MICHIGAN

COUNTY OF BERRIEN} SS.

Jennifer Lyon, being duly sworn and says that she is Inside Sales Supervisor of The Herald-Palladium, a newspaper published, printed and circulated in the County of Berrien, State of Michigan: That the annexed printed notice has been printed and published in said newspaper 1 times. Same being on the following days, to wit:

September 8, 2005

Jennifer Lyon
(Signature)

Subscribed and sworn to me this 21st Day of September A.D. 2005.

Lynne Christensen
NOTARY PUBLIC, Berrien County, Michigan
My commission expires 4-10 2006

BENTON HARBOR – ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT

Producing clean water for the environment

PUBLIC NOTICE

The Benton Harbor – St. Joseph Joint Wastewater Treatment Plant is currently and proposes to continue to receive septage waste at 269 Anchors Way, St. Joseph, Michigan 49085.

The Joint Plant's Septage Waste Treatment Operating Plan is on file and available for review upon request at the plant during normal weekday business hours.

Written comments on the operating plan will be accepted until October 10, 2005. For more information contact: Timothy J. Lynch, Manager (269) 983-7719.

BENTON HARBOR – ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT

Producing clean water for the environment

SEPTAGE WASTE TREATMENT OPERATING PLAN

SEPTEMBER 2005

The Benton Harbor – St. Joseph Joint Wastewater Treatment Plant (Joint Plant) receives septage waste at 269 Anchors Way, St. Joseph, Michigan 49085 in accordance with the Supplemental Septage Dumping and Treatment Rules and Regulations as adopted by the Benton Harbor – St. Joseph Wastewater Treatment Plant Joint Board of Commissioners (Joint Board) on December 16, 2004.

Receiving Facility Capacity: The Joint Plant has a design capacity to receive and treat 15.3 million gallons of wastewater per day (MGD) and 37,900 pounds/day of BOD. For Fiscal Year 2004-05, the Joint Plant treated an average of 9.21 MGD of wastewater and 11,033 pounds/day of BOD.

Approximately 1,000,000 gallons of septage waste is received and treated per year by the Joint Plant. The current approximate daily average of septage waste received is 3,000 gallons per day. The peak daily flow of septage received is approximately 20,000 gallons. These volumes do not pose a significant conventional load to the facility.

Receiving Facility Service Area: The service area for the receiving of septage waste for the Joint Plant consists of Berrien County and portions of Cass and Van Buren Counties in accordance with Part 117 (sec. 11701).

Hours of Operation: Septage Waste can be received between the hours of 6 a.m. to 6 p.m. Monday through Friday. Special arrangements can be made to receive waste at hours other than these.

Other Conditions: The Supplemental Septage Dumping and Treatment Rules and Regulations as adopted are attached to and included as part of the Joint Plant's Septage Waste Treatment Operating Plan.

Benton Harbor - St. Joseph Joint Wastewater Treatment Plant

SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS

December 16, 2004

REFERENCE AND AUTHORIZATION: ARTICLE IV, SECTION 413 OF THE INDUSTRIAL WASTE RULES AND REGULATIONS AS ADOPTED BY THE BENTON HARBOR - ST. JOSEPH WASTEWATER TREATMENT PLANT JOINT BOARD OF COMMISSIONERS, (JOINT BOARD), ON NOVEMBER 9, 2000.

SUPPLEMENTAL RULES AND REGULATIONS RELATING TO THE DUMPING AND TREATMENT OF DOMESTIC SEPTIC TANK WASTES (SEPTAGE) AT THE BENTON HARBOR - ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT (JOINT PLANT).

SECTION 413-1: RATES AND CHARGES, INVOICING DEPOSITS:

CHARGES FOR DUMPING AND TREATMENT OF SEPTAGE WASTE AT THE JOINT PLANT:

EFFECTIVE JANUARY 1, 2005 - \$35.00 PER 1,000 GALLONS

EFFECTIVE JULY 1, 2006 - \$40.00 PER 1,000 GALLONS

THE JOINT BOARD RESERVES THE RIGHT TO PERIODICALLY ADJUST THE CHARGE FOR DUMPING AND TREATMENT OF SEPTAGE TO REFLECT:

- 1) CHANGES IN THE BULK TREATMENT FEE FOR THE TREATMENT OF IN-SERVICE (SEWERED) CUSTOMERS OF THE JOINT PLANT.
- 2) CHANGES IN TREATMENT AND/OR CAPITAL COSTS INCURRED BY THE JOINT PLANT.
- 3) OTHER FACTORS AS DEEMED APPROPRIATE BY THE JOINT BOARD.

CHARGES FOR VOLUMES OTHER THAN SPECIFIED ABOVE SHALL BE PRORATED PER 100 GALLONS.

INVOICES WILL BE ISSUED MONTHLY BASED ON THE NUMBER OF LOADS RECEIVED AND THE RATED CAPACITY OF THE DELIVERY TRUCK(S). NO ALLOWANCE WILL BE MADE FOR PARTIAL LOADS (LESS THAN THE RATED CAPACITY OF THE DELIVERY TRUCK). A DELIVERY SLIP IDENTIFYING THE SEPTIC TANK WASTE HAULER, DELIVERY TRUCK LICENSE NUMBER, RATED TRUCK CAPACITY AND THE SOURCE OF THE SEPTAGE WASTE SHALL BE PROVIDED WITH EACH DELIVERY. PAYMENT FOR DUMPING AND TREATMENT CHARGES IS DUE UPON RECEIPT OF AN INVOICE, BUT IN NO EVENT SHALL PAYMENT EXTEND BEYOND 30-DAYS FOLLOWING THE INVOICE DATE.

A DEPOSIT MAY BE COLLECTED AND HELD AS SECURITY AGAINST FUTURE BILLINGS AND CHARGES. THE DEPOSIT WILL BE RETURNED AFTER A SATISFACTORY PAYMENT RECORD HAS BEEN ESTABLISHED. FAILURE TO PAY INVOICED AMOUNTS WILL RESULT IN THE TERMINATION OF DUMPING AUTHORIZATION AND INITIATION OF NECESSARY ACTIONS TO COLLECT PAST DUE AMOUNTS.

SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS

December 16, 2004

SECTION 413-2: GENERAL REQUIREMENTS

- A) ANY PERSON, FIRM OR COMPANY MAKING APPLICATION TO DUMP SEPTAGE AT THE JOINT PLANT SHALL:
- 1) PROCURE AND PROVIDE ALL REQUIRED STATE OF MICHIGAN AND/OR COUNTY LICENSES/PERMITS.
 - 2) PROVIDE INFORMATION IDENTIFYING THE NAME AND BUSINESS ADDRESS OF THE SEPTIC TANK WASTE HAULER AND THE LICENSE NUMBER, RATED CAPACITY AND MAKE AND MODEL YEAR OF THE DELIVERY TRUCKS.
 - 3) PROVIDE SATISFACTORY EVIDENCE OF PROOF OF AUTOMOTIVE LIABILITY AND PROPERTY DAMAGE INSURANCE. (FAILURE TO MAINTAIN SATISFACTORY INSURANCE WILL RESULT IN TERMINATION OF DUMPING AUTHORIZATION).
- B) WRITTEN AUTHORIZATION SHALL BE OBTAINED FROM THE JOINT BOARD TO DUMP SEPTAGE WASTE AT THE JOINT PLANT. DUMPING AUTHORIZATION SHALL BE SUBJECT TO ANNUAL RENEWAL AND MAY BE RESCINDED AT ANY TIME FOR FAILURE TO FULLY COMPLY WITH PROVISIONS OF THESE SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS AND/OR THE JOINT BOARD INDUSTRIAL WASTE RULES AND REGULATIONS.
- C) A STATEMENT SHALL BE FILED ANNUALLY CERTIFYING THAT SEPTAGE DUMPED AT THE JOINT PLANT COMPLIES WITH THE REQUIREMENTS OF THESE SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS AND THE PROVISIONS OF THE AFOREMENTIONED INDUSTRIAL WASTE RULES AND REGULATIONS.
- D) SEPTAGE WASTE SHALL BE STRICTLY INTERPRETED TO MEAN WASTE RESULTING FROM SANITARY AND/OR DOMESTIC SOURCES. THE DUMPING OF ANY WATER OR WASTE ORIGINATING FROM AN INDUSTRIAL OR COMMERCIAL PROCESS OR THE SLUDGE, PRECIPITATE OR CONGEALED SUBSTANCES RESULTING FROM ANY PERSON'S WATER, WASTE OR AIR POLLUTANTS AS DEFINED BY THE JOINT BOARD'S INDUSTRIAL WASTE RULES AND REGULATIONS IS PROHIBITED.
- E) THE JOINT BOARD RESERVES THE RIGHT TO SEEK CIVIL AND/OR CRIMINAL ACTION AGAINST ANY SEPTIC TANK WASTE HAULER FOR THE DUMPING OF WATER OR WASTE MATERIAL NOT IN CONFORMANCE WITH THESE SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS AND/OR THE INDUSTRIAL WASTE RULES AND REGULATIONS AND TO SEEK MONETARY RECOVERY FOR ANY ADDITIONAL COSTS ASSOCIATED WITH THE HANDLING, TREATMENT AND/OR DISPOSAL OF SUCH WASTE MATERIAL(S).
- F) THE JOINT BOARD RESERVES THE RIGHT TO REFUSE SERVICE TO ANYONE DISCHARGING WATER OR WASTE WHICH MAY BE HARMFUL TO, IMPAIR, OR INTERFERE WITH THE OPERATION OF THE JOINT PLANT, ITS TREATMENT PROCESSES, EFFLUENT TREATED WATER QUALITY, OR RESIDUAL SOLIDS HANDLING METHODS.
- G) THE JOINT BOARD MAY PERIODICALLY SAMPLE AND ANALYZE SEPTAGE WASTE TO VERIFY THAT SUBSTANCES WHICH MAY EXCEED APPLICABLE PROVISIONS INDUSTRIAL WASTE RULES AND REGULATIONS, AND/OR "LOCAL LIMITS" AS ADOPTED BY THE JOINT BOARD, ARE NOT PRESENT IN THE SEPTAGE WASTE.
- H) THE JOINT BOARD RESERVES THE RIGHT TO ESTABLISH SPECIFIC HOURS DURING WHICH SEPTAGE MAY BE DUMPED AT THE JOINT PLANT.
- I) SEPTIC TANK WASTE HAULERS SHALL KEEP THE JOINT PLANT'S SEPTAGE RECEIVING TANK AREA CLEAN AND WASHED DOWN FOLLOWING EACH DUMP CYCLE.

BENTON HARBOR – ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT

Producing clean water for the environment

October 10, 2005

Mr. Matthew Campbell
Septage Waste Program Coordinator
MDEQ Water Bureau
PO Box 30273
Lansing, MI 48909-7773

Subject: Septage Waste Treatment Operating Plan

Dear Mr. Campbell:

Enclosed you will find the proposed operating plan relating to the Joint Plant's treatment of septage waste. The public notice requirements have been fulfilled and an Affidavit of Publication for such is on file.

The latest amendment to the rules and regulations governing the treatment of septage waste was approved and adopted by the Benton Harbor – St. Joseph Wastewater Treatment Plant Joint Board of Commissioners on December 16, 2004. These rules form the basis for the Joint Plant's Septage Waste Treatment Operating Plan.

If you have any questions or comments relating to this matter please contact me.

Sincerely,



Timothy J. Lynch
Plant Manager

Enclosures

RECEIVED
MICH. DEPT. OF ENVIRONMENTAL QUALITY

OCT 13 2005

WATER BUREAU
DWEHS

BENTON HARBOR – ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT

Producing clean water for the environment

SEPTAGE WASTE TREATMENT OPERATING PLAN

SEPTEMBER 2005

The Benton Harbor - St. Joseph Joint Wastewater Treatment Plant (Joint Plant) receives septage waste at 269 Anchors Way, St. Joseph, Michigan 49085 in accordance with the Supplemental Septage Dumping and Treatment Rules and Regulations as adopted by the Benton Harbor - St. Joseph Wastewater Treatment Plant Joint Board of Commissioners (Joint Board) on December 16, 2004.

Receiving Facility Capacity: The Joint Plant has a design capacity to receive and treat 15.3 million gallons of wastewater per day (MGD) and 37,900 pounds/day of BOD. For Fiscal Year 2004-05, the Joint Plant treated an average of 9.21 MGD of wastewater and 11,033 pounds/day of BOD.

Approximately 1,000,000 gallons of septage waste is received and treated per year by the Joint Plant. The current approximate daily average of septage waste received is 3,000 gallons per day. The peak daily flow of septage received is approximately 20,000 gallons. These volumes do not pose a significant conventional load to the facility.

Receiving Facility Service Area: The service area for the receiving of septage waste for the Joint Plant consists of Berrien County and portions of Cass and Van Buren Counties in accordance with Part 117 (sec. 11701).

Hours of Operation: Septage Waste can be received between the hours of 6 a.m. to 6 p.m. Monday through Friday. Special arrangements can be made to receive waste at hours other than these.

Other Conditions: The Supplemental Septage Dumping and Treatment Rules and Regulations as adopted are attached to and included as part of the Joint Plant's Septage Waste Treatment Operating Plan.

RECEIVED
MICH. DEPT. OF ENVIRONMENTAL QUALITY

OCT 13 2005

WATER BUREAU
DWERS

Benton Harbor - St. Joseph Joint Wastewater Treatment Plant

SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS

December 16, 2004

REFERENCE AND AUTHORIZATION: ARTICLE IV, SECTION 413 OF THE INDUSTRIAL WASTE RULES AND REGULATIONS AS ADOPTED BY THE BENTON HARBOR - ST. JOSEPH WASTEWATER TREATMENT PLANT JOINT BOARD OF COMMISSIONERS, (JOINT BOARD), ON NOVEMBER 9, 2000.

SUPPLEMENTAL RULES AND REGULATIONS RELATING TO THE DUMPING AND TREATMENT OF DOMESTIC SEPTIC TANK WASTES (SEPTAGE) AT THE BENTON HARBOR - ST. JOSEPH JOINT WASTEWATER TREATMENT PLANT (JOINT PLANT).

SECTION 413-1: RATES AND CHARGES, INVOICING DEPOSITS:

CHARGES FOR DUMPING AND TREATMENT OF SEPTAGE WASTE AT THE JOINT PLANT:

EFFECTIVE JANUARY 1, 2005 - \$35.00 PER 1,000 GALLONS

EFFECTIVE JULY 1, 2006 - \$40.00 PER 1,000 GALLONS

THE JOINT BOARD RESERVES THE RIGHT TO PERIODICALLY ADJUST THE CHARGE FOR DUMPING AND TREATMENT OF SEPTAGE TO REFLECT:

- 1) CHANGES IN THE BULK TREATMENT FEE FOR THE TREATMENT OF IN-SERVICE (SEWERED) CUSTOMERS OF THE JOINT PLANT.
- 2) CHANGES IN TREATMENT AND/OR CAPITAL COSTS INCURRED BY THE JOINT PLANT.
- 3) OTHER FACTORS AS DEEMED APPROPRIATE BY THE JOINT BOARD.

CHARGES FOR VOLUMES OTHER THAN SPECIFIED ABOVE SHALL BE PRORATED PER 100 GALLONS.

INVOICES WILL BE ISSUED MONTHLY BASED ON THE NUMBER OF LOADS RECEIVED AND THE RATED CAPACITY OF THE DELIVERY TRUCK(S). NO ALLOWANCE WILL BE MADE FOR PARTIAL LOADS (LESS THAN THE RATED CAPACITY OF THE DELIVERY TRUCK). A DELIVERY SLIP IDENTIFYING THE SEPTIC TANK WASTE HAULER, DELIVERY TRUCK LICENSE NUMBER, RATED TRUCK CAPACITY AND THE SOURCE OF THE SEPTAGE WASTE SHALL BE PROVIDED WITH EACH DELIVERY. PAYMENT FOR DUMPING AND TREATMENT CHARGES IS DUE UPON RECEIPT OF AN INVOICE, BUT IN NO EVENT SHALL PAYMENT EXTEND BEYOND 30-DAYS FOLLOWING THE INVOICE DATE.

A DEPOSIT MAY BE COLLECTED AND HELD AS SECURITY AGAINST FUTURE BILLINGS AND CHARGES. THE DEPOSIT WILL BE RETURNED AFTER A SATISFACTORY PAYMENT RECORD HAS BEEN ESTABLISHED. FAILURE TO PAY INVOICED AMOUNTS WILL RESULT IN THE TERMINATION OF DUMPING AUTHORIZATION AND INITIATION OF NECESSARY ACTIONS TO COLLECT PAST DUE AMOUNTS.

RECEIVED
MICH. DEPT. OF ENVIRONMENTAL QUALITY

OCT 13 2005

SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS

December 16, 2004

SECTION 413-2: GENERAL REQUIREMENTS

- A) ANY PERSON, FIRM OR COMPANY MAKING APPLICATION TO DUMP SEPTAGE AT THE JOINT PLANT SHALL:
- 1) PROCURE AND PROVIDE ALL REQUIRED STATE OF MICHIGAN AND/OR COUNTY LICENSES/PERMITS.
 - 2) PROVIDE INFORMATION IDENTIFYING THE NAME AND BUSINESS ADDRESS OF THE SEPTIC TANK WASTE HAULER AND THE LICENSE NUMBER, RATED CAPACITY AND MAKE AND MODEL YEAR OF THE DELIVERY TRUCKS.
 - 3) PROVIDE SATISFACTORY EVIDENCE OF PROOF OF AUTOMOTIVE LIABILITY AND PROPERTY DAMAGE INSURANCE. (FAILURE TO MAINTAIN SATISFACTORY INSURANCE WILL RESULT IN TERMINATION OF DUMPING AUTHORIZATION).
- B) WRITTEN AUTHORIZATION SHALL BE OBTAINED FROM THE JOINT BOARD TO DUMP SEPTAGE WASTE AT THE JOINT PLANT. DUMPING AUTHORIZATION SHALL BE SUBJECT TO ANNUAL RENEWAL AND MAY BE RESCINDED AT ANY TIME FOR FAILURE TO FULLY COMPLY WITH PROVISIONS OF THESE SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS AND/OR THE JOINT BOARD INDUSTRIAL WASTE RULES AND REGULATIONS.
- C) A STATEMENT SHALL BE FILED ANNUALLY CERTIFYING THAT SEPTAGE DUMPED AT THE JOINT PLANT COMPLIES WITH THE REQUIREMENTS OF THESE SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS AND THE PROVISIONS OF THE AFOREMENTIONED INDUSTRIAL WASTE RULES AND REGULATIONS.
- D) SEPTAGE WASTE SHALL BE STRICTLY INTERPRETED TO MEAN WASTE RESULTING FROM SANITARY AND/OR DOMESTIC SOURCES. THE DUMPING OF ANY WATER OR WASTE ORIGINATING FROM AN INDUSTRIAL OR COMMERCIAL PROCESS OR THE SLUDGE, PRECIPITATE OR CONGEALED SUBSTANCES RESULTING FROM ANY PERSON'S WATER, WASTE OR AIR POLLUTANTS AS DEFINED BY THE JOINT BOARD'S INDUSTRIAL WASTE RULES AND REGULATIONS IS PROHIBITED.
- E) THE JOINT BOARD RESERVES THE RIGHT TO SEEK CIVIL AND/OR CRIMINAL ACTION AGAINST ANY SEPTIC TANK WASTE HAULER FOR THE DUMPING OF WATER OR WASTE MATERIAL NOT IN CONFORMANCE WITH THESE SUPPLEMENTAL SEPTAGE DUMPING AND TREATMENT RULES AND REGULATIONS AND/OR THE INDUSTRIAL WASTE RULES AND REGULATIONS AND TO SEEK MONETARY RECOVERY FOR ANY ADDITIONAL COSTS ASSOCIATED WITH THE HANDLING, TREATMENT AND/OR DISPOSAL OF SUCH WASTE MATERIAL(S).
- F) THE JOINT BOARD RESERVES THE RIGHT TO REFUSE SERVICE TO ANYONE DISCHARGING WATER OR WASTE WHICH MAY BE HARMFUL TO, IMPAIR, OR INTERFERE WITH THE OPERATION OF THE JOINT PLANT, ITS TREATMENT PROCESSES, EFFLUENT TREATED WATER QUALITY, OR RESIDUAL SOLIDS HANDLING METHODS.
- G) THE JOINT BOARD MAY PERIODICALLY SAMPLE AND ANALYZE SEPTAGE WASTE TO VERIFY THAT SUBSTANCES WHICH MAY EXCEED APPLICABLE PROVISIONS INDUSTRIAL WASTE RULES AND REGULATIONS, AND/OR "LOCAL LIMITS" AS ADOPTED BY THE JOINT BOARD, ARE NOT PRESENT IN THE SEPTAGE WASTE.
- H) THE JOINT BOARD RESERVES THE RIGHT TO ESTABLISH SPECIFIC HOURS DURING WHICH SEPTAGE MAY BE DUMPED AT THE JOINT PLANT.
- I) SEPTIC TANK WASTE HAULERS SHALL KEEP THE JOINT PLANT'S SEPTAGE RECEIVING TANK AREA CLEAN AND WASHED DOWN FOLLOWING EACH DUMP CYCLE.